

**WENDELL HANCOCK** registered public surveyor no. 1326

1721 HALTOM ROAD

FORT WORTH, TEXAS 76117

PHONE 834-6243



Oct. 23, 1995

City of Benbrook  
Building Inspection Dept.  
911 Winscott Plover Road  
Benbrook, Texas 76126


RE: LOT 9, BLOCK 24, MEADOW PARK ADDITION  
PHASE VII  
6608 Meadow Park Court

Dear Sir:

I have run the finished floor elevation of the residence on the above referenced lot and find that the elevation of the existing residence is 612.62 feet. This is above the required finished floor elevation of 611.5 feet as shown on the recorded plat and should meet all requirements of the City.

The benchmark used to determine this elevation is a square box cut on the Southeast corner of inlet 100 feet South of the intersection of Bellaire Brive and Legend Road, on the West side of Bellaire Drive. The elevation shown is 608.69 feet.

Sincerely,

  
Wendell Hancock

